



TECHNICAL POLICY

14 – 01 Class I Standpipe Outlets – 2 ½ Inch Hose Valves

Original Issue: February 1985
Revised: April 2006

1. The hose valve outlet is to be located to provide a minimum of 12 inch radius clear space for a spanner wrench.
2. Standpipe and hose valves are to be located so as to not interfere with the required exit width of the stairs (usually 44 inches).
3. 2 ½ x 1 ½ inch reducers are not required on 2 ½ inch hose valves.
4. Hose valves are required at all intermediate landings or floor level landings including ground or first floor. The valves in a given stairway shall be either all on the intermediate landings or all on the floor level landings.