



TECHNICAL POLICY

20 – 04 Fire Pump Suction Pipe

Original Issue: August 1998
Revised: April 2006

The pipe and fittings from the city water main to the detector check valve shall meet the requirements of the Minneapolis Water Department.

The piping from the detector check valve to the suction side of the fire pump is to be galvanized.