



TECHNICAL POLICY

13 – 43 One Inch Outlets for Future Ceilings

Original Issue: May 1999
Revised: April 2006

One inch outlets shall be provided in sprinkler systems in speculative warehouses or buildings where finished areas have not been identified at the time of the design of the system. The number and location of the outlets is to be such as to adequately supply sprinklers under a future ceiling.

Any of the following can provide the outlets:

1. Plugged outlets.
2. Hexagonal bushings in the fittings that supply sprinklers.
3. One inch pipe with reducing couplings supplying sprinklers.