



NOTE:  
 CABINET ANCHORS ARE HILTI KWIK  
 BOLT II WEDGE ANCHOR OR EQUAL,  
 4 PER CABINET, 1/2" x 4 1/2" STAINLESS  
 STEEL (#304) FULL THREADED.

- ① PROVIDE PROTECTIVE BUSHINGS ON ALL CONDUITS.
- ② ELECTRICAL CONDUITS AS SPECIFIED.
- ③ KEEP SERVICE FEED TO LEFT OF BARRIER.

NO SCALE

|   |  |              |  |                                       |
|---|--|--------------|--|---------------------------------------|
|  | <b>MINNEAPOLIS</b><br>DEPARTMENT OF PUBLIC WORKS |              | FOUNDATION - ST. LIGHT<br>TWO SERVICE CABINETS | STANDARD<br>PLATE<br>NO.<br>TRAF-3088 |
|   | DRAWN: LPK                                       | DATE: 1/1/11 |  |                                       |