

TEMPORARY HEAT REQUIREMENTS

October 23, 2014

ONLY LICENSED MECHANICAL CONTRACTORS CAN INSTALL CONSTRUCTION HEATERS

1. 25 feet of the flexible hose is the maximum allowed unless pre-approved by the mechanical inspector
2. Flexible hose will be installed a minimum of 3 1/2 inches off the ground, supported, and out of the way of any construction traffic
3. ALL flexible hoses must pass a 25 pound (minimum) 12 hour pressure test
4. ALL locating and RELOCATING of construction heaters will be done ONLY by the licensed permitting contractor's gasfitter.
5. 100 % outdoor air will be supplied to the construction heater at all times.
6. An approved manual shut off valve shall be installed at each unit
7. All construction heater permits must be renewed after 1 year
8. All propane (LP) tanks will be installed and sited per NFPA 58

ANY VIOLATION OF THE ABOVE COULD LEAD TO TAGS ISSUED OR MAY RESULT IN THE UNIT(S) BEING SHUT OFF BY THE INSPECTOR